

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name **Humbug Mtn SP**

PWS ID# **41 91018**

Month/Year **02/2024** Entry Point: **WTP-A**

Required Minimum Residual **0.3 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8:10A		.70	Shop SH
2	8:15A		.68	Shop SH
3	8:20A		.67	Shop SH
4	8:00A		.75	Shop GW
5	8:00A		.70	Shop GW
6	8:15A		.70	Shop SH
7	8:10A		.72	Shop SH
8	8:15A		.83	Shop SH
9	8:10A		.78	Shop SH
10	8:10A		.73	Shop SH
11	8:10A		.84	Shop PH
12	8:45A		.80	Shop PH
13	8:15A		.83	Shop SH
14	8:20A		.76	Shop SH
15	8:25A		.79	Shop SH
16	8:00A		.90	Shop GW
17	8:25A		.79	Shop SH
18	8:00A		.83	Shop GW
19	8:00A		.91	Shop GW
20	8:00A		.72	Shop GW
21	8:20A		.74	Shop SH
22	8:10A		.82	Shop SH
23	8:05A		.77	Shop SH
24	8:05A		.74	Shop SH
25	8:20A		.88	Shop PH
26	8:45A		.96	Shop PH
27	8:30A		.68	Shop SH
28	8:15A		.61	Shop SH
29	8:45A		.75	Shop SH
30	<i>[Handwritten signature]</i>			
31	<i>[Handwritten signature]</i>			

Was the chlorine residual ever less than the required minimum residual of 0.3 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? hours - if > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: Steve Husted Title: Park Ranger Operator Certification #: _____
 Signature: [Signature] Phone #: (541) 332-6774 OR
 Date: 02/29/24 Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.