

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name OPRD Cove Park - Deschutes

PWS ID# 41 91036

Month/Year 03/2022

Entry Point:

Required Minimum Residual .5 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	8am	AA-Well#1	0.82	Taken at shop
2	10am	AA-Well#1	0.82	Taken at shop
3	10:30am	AA-Well#1	0.91	Taken at shop
4	10:30am	AA-Well#1	1.03	Taken at shop
5	8:45am	AA-Well#1	1.06	Taken at shop
6	9am	AA-Well#1	0.83	Taken at shop
7	9:30am	AA-Well#1	0.87	Taken at shop
8	12pm	AA-Well#1	0.89	Taken at shop
9	10am	AA-Well#1	0.83	Taken at shop
10	9am	AA-Well#1	0.96	Taken at shop
11	10:10am	AA-Well#1	0.84	Taken at shop
12	9am	AA-Well#1	0.83	Taken at shop
13	9am	AA-Well#1	0.80	Taken at shop
14	9am	AA-Well#1	0.81	Taken at shop
15	9am	AA-Well#1	0.63	Taken at shop
16	9am	AA-Well#1	0.71	Taken at shop
17	11am	AA-Well#1	0.66	Taken at shop
18	10am	AA-Well#1	0.54	Taken at shop
19	9am	AA-Well#1	0.56	Taken at shop
20	9am	AA-Well#1	0.56	Taken at shop
21	10am	AA-Well#1	0.70	Taken at shop
22	10am	AA-Well#1	0.70	Taken at shop
23	10am	AA-Well#1	0.75	Taken at shop
24	9:30am	AA-Well#1	0.79	Taken at shop
25	9:30am	AA-Well#1	0.81	Taken at shop
26	9am	AA-Well#1	1.02	Taken at shop
27	9am	AA-Well#1	0.71	Taken at shop
28	9:30am	AA-Well#1	0.63	Taken at shop
29	9:30am	AA-Well#1	0.56	Taken at shop
30	9:30am	AA-Well#1	0.63	Taken at shop
31	9am	AA-Well#1	0.56	Taken at shop

Was the chlorine residual ever less than the required minimum residual of 0.5 mg/L?  Yes  No

If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required?  Yes  No

*Attach those results and submit them with this form.*

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No

*Attach grab sample results and submit them with this form.*

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: Sharlyn Longoria

Title: Park Specialist

Operator Certification #:

Signature: 

Phone #: (541) 546-3412

OR

Date: 03/31/2022

Small Groundwater System X

**Return by 10<sup>th</sup> of following month by either email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.**