

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name OPRD Cove Park - Deschutes

PWS ID# 4 1 91036

Month/Year July 2023 Entry Point:


Required Minimum Residual .5 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:45AM	AA-Well#1	.81	Taken at shop
2	7:40AM	AA-Well#1	1.13	Taken at shop
3	8AM	AA-Well#1	1.29	Taken at shop
4	7:45AM	AA-Well#1	1.29	Taken at shop
5	7:45AM	AA-Well#1	.98	Taken at shop
6	8:30AM	AA-Well#1	1.26	Taken at shop
7	2:30PM	AA-Well#1	1.44	Taken at shop
8	8:10AM	AA-Well#1	1.16	Taken at shop
9	7:50AM	AA-Well#1	1.0	Taken at shop
10	8:10AM	AA-Well#1	.90	Taken at shop
11	8:10AM	AA-Well#1	1.13	Taken at shop
12	8:24AM	AA-Well#1	.97	Taken at shop
13	7:30AM	AA-Well#1	.95	Taken at shop
14	7:48AM	AA-Well#1	.75	Taken at shop
15	8:02AM	AA-Well#1	.63	Taken at shop
16	8:12AM	AA-Well#1	1.12	Taken at shop
17	8AM	AA-Well#1	.69	Taken at shop
18	8AM	AA-Well#1	.88	Taken at shop
19	8AM	AA-Well#1	.90	Taken at shop
20	8AM	AA-Well#1	.69	Taken at shop
21	8AM	AA-Well#1	.95	Taken at shop
22	8:20AM	AA-Well#1	.79	Taken at shop
23	8:20AM	AA-Well#1	.76	Taken at shop
24	7:45AM	AA-Well#1	.55	Taken at shop
25	7:45AM	AA-Well#1	.95	Taken at shop
26	7:30AM	AA-Well#1	.79	Taken at shop
27	7:52AM	AA-Well#1	1.13	Taken at shop
28	8:22AM	AA-Well#1	.81	Taken at shop
29	8:10AM	AA-Well#1	1.01	Taken at shop
30	8:36AM	AA-Well#1	1.01	Taken at shop
31	8:30AM	AA-Well#1	.87	Taken at shop

Was the chlorine residual ever less than the required minimum residual of 0.5 mg/L? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer	GWS Serving More Than 3,300	
If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach those results and submit them with this form.	Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach grab sample results and submit them with this form.	Date continuous monitoring equipment failed: / / Date it was returned to service: / /

Printed Name: SHARLYN LONGORIA Signature:  Date: 08/02/2023	Title: Park Specialist Phone #: (541) 546-3412	Operator Certification #: OR Small Groundwater System X
--	---	---

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.