State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

| System Name OPRD Cove Park - Deschutes PWS ID# 4 1 91036 | | | | | | | |
|--|--------|------------------|---|--|---------------------------|--|--|
| Month/Year 3/2025 Entry Point: DESCHUTES Required Minimum Residual .5 mg/L | | | | | | | |
| Date | Time | Source(s) in use | | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes | | |
| 1 | 9AM | AA-Well#1 | | .64 | Taken at shop | | |
| 2 | 9:15AM | AA-Well#1 | | .61 | Taken at shop | | |
| 3 | 8AM | AA-Well#1 | | .72 | Taken at shop | | |
| 4 | 8:20AM | AA-Well#1 | | .59 | Taken at shop | | |
| 5 | 8:15AM | AA-Well#1 | | .62 | Taken at shop | | |
| 6 | 8:15AM | AA-Well#1 | | .73 | Taken at shop | | |
| 7 | 8:45AM | AA-Well#1 | | .61 | Taken at shop | | |
| 8 | 9:30AM | AA-Well#1 | | .63 | Taken at shop | | |
| 9 | 9AM | AA-Well#1 | | .56 | Taken at shop | | |
| 10 | 8:30AM | AA-Well#1 | | .65 | Taken at shop | | |
| 11 | 5:30PM | AA-Well#1 | | .62 | Taken at shop | | |
| 12 | 8:30AM | AA-Well#1 | | .67 | Taken at shop | | |
| 13 | 8:30AM | AA-Well#1 | | .59 | Taken at shop | | |
| 14 | 9AM | AA-Well#1 | | .65 | Taken at shop | | |
| 15 | 9:45AM | AA-Well#1 | | .57 | Taken at shop | | |
| 16 | 9AM | AA-Well#1 | | .59 | Taken at shop | | |
| 17 | 8:30AM | AA-Well#1 | | .62 | Taken at shop | | |
| 18 | 9AM | AA-Well#1 | | .64 | Taken at shop | | |
| 19 | 6PM | AA-Well#1 | | .63 | Taken at shop | | |
| 20 | 1PM | AA-Well#1 | | .57 | Taken at shop | | |
| 21 | 8:30AM | AA-Well#1 | | .50 | Taken at shop | | |
| 22 | 9:30AM | AA-Well#1 | | .63 | Taken at shop | | |
| 23 | 9:30AM | AA-Well#1 | | .58 | Taken at shop | | |
| 24 | 9:30AM | AA-Well#1 | | .58 | Taken at shop | | |
| 25 | 8:30AM | AA-Well#1 | | .64 | Taken at shop | | |
| 26 | 8:30AM | AA-Well#1 | | .57 | Taken at shop | | |
| 27 | 8:30AM | AA-Well#1 | | .62 | Taken at shop | | |
| 28 | 8:30AM | AA-Well#1 | | .74 | Taken at shop | | |
| 29 | 9AM | AA-Well#1 | | .53 | Taken at shop | | |
| 30 | 9AM | AA-Well#1 | | .65 | Taken at shop | | |
| 31 | 9AM | AA-Well#1 | | .66 | Taken at shop | | |
| Was the chlorine residual ever less than the required minimum residual of 0.5 mg/L? Yes X No | | | | | | | |
| If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day. | | | | | | | |
| GWS Serving 3,300 or Fewer GWS Serving More Than 3,300 | | | | | | | |
| If yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No If yes Attach those results and submit them with this form. | | | Did continuous monitoring equipment fail at any reporting month? ☐ Yes ☐ No | | | Date continuous monitoring equipment failed: | |
| | | | If yes, were ara | f yes, were grab samples collected every four | | hours until the / / | |
| | | | continuous monitoring equipment was returned required? Yes No | | | | |
| | | | | | | service: | |
| Attach grab sample results and submit them with this form. | | | | | | | |
| Printed Name: SHARLYN LONGORIA Title: PARK SPECIALIST | | | | | Operator Certification #: | | |
| Signature: Tharlyn Ungaha Phone #: (541) 546-3412 | | | | | OR | | |
| Date: 4/ | | 0 | Small G | Small Groundwater System X | | | |