

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name: Cascadia Linn County Park

PWS ID# 41 91055

Month/Year April 2025

Entry Point: Pump House

Required Minimum Residual .2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1				
2				
3				
4				
5				
6				
7				
8	2:50pm	Behind Day Use CXT	0.45	KP
9	1:03pm	" "	0.24	KP
10	2:08pm	" "	0.65	KP
11	10:01am	" "	0.76	KP
12	3:57pm	" "	0.75	CE
13	2:10pm	" "	0.8	DD
14	3:07pm	" "	0.81	KP
15	1:35pm	" "	0.88	KP
16	11:00am	" "	0.82	KP
17	2:35pm	" "	0.86	KP
18	1:54pm	" "	0.77	KP
19	11:07am	" "	0.81	CE
20	1:09pm	" "	0.83	DD
21	12:37pm	" "	0.89	KP
22	3:41pm	" "	0.89	KP
23	3:35pm	" "	1.1	CE
24	3:37pm	" "	0.91	KP
25	4:08pm	" "	0.39	KP
26	3:48pm	" "	0.47	CE
27	10:04am	" "	0.45	DD
28	1:23pm	" "	0.42	KP
29	2:37pm	" "	0.4	KP
30	4:40pm	" "	0.68	KP
31				

Was the chlorine residual ever less than the required minimum residual of .2 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab samples results and submit them with this form.

Printed Name: Adam Brenneman

Signature: 

Date: 5/01/2025

Title: Assistant Supervisor

Phone #: (541) 801-4767

Operator Certification #:

OR

Small Groundwater System Yes