

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name		TU-TU-TUN LODGE / FOUR SEASONS RESORT		PWS ID#	4 1 91199
Month/Year		JULY 2025		Entry Point:	EP-A
				Required Minimum Residual	1.50 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10AM	SRC AB-WELL L122738	1.70	
2	10AM	SRC AB-WELL L122738	1.70	
3	10AM	SRC AB-WELL L122738	1.74	
4	10AM	SRC AB-WELL L122738	1.71	
5	10AM	SRC AB-WELL L122738	1.76	
6	11AM	SRC AB-WELL L122738	1.68	
7	11AM	SRC AB-WELL L122738	1.64	
8	9AM	SRC AB-WELL L122738	1.67	
9	9AM	SRC AB-WELL L122738	1.75	
10	9AM	SRC AB-WELL L122738	1.77	
11	9AM	SRC AB-WELL L122738	1.71	
12	10AM	SRC AB-WELL L122738	1.65	
13	10AM	SRC AB-WELL L122738	1.68	
14	10AM	SRC AB-WELL L122738	1.62	
15	10AM	SRC AB-WELL L122738	1.58	
16	10AM	SRC AB-WELL L122738	1.61	
17	9AM	SRC AB-WELL L122738	1.56	
18	11AM	SRC AB-WELL L122738	1.61	
19	9AM	SRC AB-WELL L122738	1.54	
20	10AM	SRC AB-WELL L122738	1.78	
21	10AM	SRC AB-WELL L122738	1.72	
22	10AM	SRC AB-WELL L122738	1.59	
23	10AM	SRC AB-WELL L122738	1.68	
24	11AM	SRC AB-WELL L122738	1.74	
25	10AM	SRC AB-WELL L122738	1.61	
26	10AM	SRC AB-WELL L122738	1.57	
27	1PM	SRC AB-WELL L122738	1.62	
28	10AM	SRC AB-WELL L122738	1.75	
29	10AM	SRC AB-WELL L122738	1.86	
30	11AM	SRC AB-WELL L122738	1.91	
31	10AM	SRC AB-WELL L122738	1.83	

Was the chlorine residual ever less than the required minimum residual of mg/L? No

If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	--	---

Printed Name: MARCUS D HARSHMAN	Title: MAINTENANCE MANAGER	Operator Certification #:
Signature:	Phone #: (541) 247-6664	OR

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

Date: 08-02-25

Small Groundwater System
41-91199

*Return by 10th of following month by either email dlwp.dmce@odhsoha.oregon.gov ; fax 971-673-0458; or mail to
Drinking Water Services, PO Box 14450, Portland, OR 97293-0450.*

March 25, 2024