

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name TU-TU-TUN LODGE / FOUR SEASONS RESORT			PWS ID# 41 91199	
Month/Year 		Entry Point: EP-A		Required Minimum Residual 1.50 mg/L
Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9AM	SRC AB-WELL L122738	1.65	
2	9AM	SRC AB-WELL L122738	1.61	
3	8AM	SRC AB-WELL L122738	1.57	
4	9AM	SRC AB-WELL L122738	1.59	
5	9AM	SRC AB-WELL L122738	1.62	
6	9AM	SRC AB-WELL L122738	1.60	
7	8AM	SRC AB-WELL L122738	1.63	
8	9AM	SRC AB-WELL L122738	1.66	
9	9AM	SRC AB-WELL L122738	1.70	
10	9AM	SRC AB-WELL L122738	1.67	
11	9AM	SRC AB-WELL L122738	1.64	
12	9AM	SRC AB-WELL L122738	1.68	
13	9AM	SRC AB-WELL L122738	1.63	
14	10AM	SRC AB-WELL L122738	1.63	
15	10AM	SRC AB-WELL L122738	1.67	
16	9AM	SRC AB-WELL L122738	1.59	
17	9AM	SRC AB-WELL L122738	1.70	
18	10AM	SRC AB-WELL L122738	1.72	
19	10AM	SRC AB-WELL L122738	1.68	
20	10AM	SRC AB-WELL L122738	1.72	
21	10AM	SRC AB-WELL L122738	1.73	
22	9AM	SRC AB-WELL L122738	1.66	
23	12PM	SRC AB-WELL L122738	1.62	
24	9AM	SRC AB-WELL L122738	1.66	
25	10AM	SRC AB-WELL L122738	1.58	
26	11AM	SRC AB-WELL L122738	1.69	
27	9AM	SRC AB-WELL L122738	1.71	
28	9AM	SRC AB-WELL L122738	1.63	
29	10AM	SRC AB-WELL L122738	1.60	
30	10AM	SRC AB-WELL L122738	1.67	
Was the chlorine residual ever less than the required minimum residual of mg/L? No If yes, what was the longest time period until the required level was restored? hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.				
GWS Serving 3,300 or Fewer If yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No <i>Attach those results and submit them with this form.</i>		GWS Serving More Than 3,300 Did continuous monitoring equipment fail at any time this reporting month? No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No <i>Attach grab sample results and submit them with this form.</i>		Date continuous monitoring equipment failed: / / Date it was returned to service: / /
Printed Name: MARCUS D HARSHMAN Signature: Date: DEC.03/2025			Title: MAINTENANCE MANAGER Phone #: (541) 247-6664	Operator Certification #: OR Small Groundwater System

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

PWS 41-91199

*Return by 10th of following month by either email dwp.dmce@odhsoha.oregon.gov ; fax 971-673-0458; or mail to
Drinking Water Services, PO Box 14450, Portland, OR 97293-0450.*

March 25, 2024