

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name	TU-TU-TUN LODGE / FOUR SEASONS RESORT	PWS ID#	4 1 91199
Month/Year	Entry Point: EP-A	Required Minimum Residual	1.50 mg/L
MAR 2026			

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10AM	SRC AB-WELL L122738	1.67	
2	10AM	SRC AB-WELL L122738	1.65	
3	10AM	SRC AB-WELL L122738	1.65	
4	10AM	SRC AB-WELL L122738	1.69	
5	10AM	SRC AB-WELL L122738	1.66	
6	10AM	SRC AB-WELL L122738	1.64	
7	10AM	SRC AB-WELL L122738	1.63	
8	9AM	SRC AB-WELL L122738	1.65	
9	9AM	SRC AB-WELL L122738	1.51	
10	10AM	SRC AB-WELL L122738	1.61	
11	10AM	SRC AB-WELL L122738	1.63	
12	10AM	SRC AB-WELL L122738	1.66	
13	10AM	SRC AB-WELL L122738	1.68	
14	10AM	SRC AB-WELL L122738	1.68	
15	10AM	SRC AB-WELL L122738	1.65	
16	10AM	SRC AB-WELL L122738	1.64	
17	10AM	SRC AB-WELL L122738	1.72	
18	9AM	SRC AB-WELL L122738	1.73	
19	9AM	SRC AB-WELL L122738	1.75	
20	9AM	SRC AB-WELL L122738	1.74	
21	9AM	SRC AB-WELL L122738	1.73	
22	9AM	SRC AB-WELL L122738	1.63	
23	9AM	SRC AB-WELL L122738	1.65	
24	9AM	SRC AB-WELL L122738	1.77	
25	9AM	SRC AB-WELL L122738	1.66	
26	10AM	SRC AB-WELL L122738	1.74	
27	10AM	SRC AB-WELL L122738	1.73	
28	9AM	SRC AB-WELL L122738	1.73	
29	9AM	SRC AB-WELL L122738	1.75	
30	9AM	SRC AB-WELL L122738	1.71	
31	9AM	SRC AB-WELL L122738	1.63	

Was the chlorine residual ever less than the required minimum residual of mg/L? No
 If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer If yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No <i>Attach those results and submit them with this form.</i></p>	<p style="text-align: center;">GWS Serving More Than 3,300</p> <table style="width: 100%;"> <tr> <td style="width: 50%;"> Did continuous monitoring equipment fail at any time this reporting month? No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No <i>Attach grab sample results and submit them with this form.</i> </td> <td style="width: 50%;"> Date continuous monitoring equipment failed: / / Date it was returned to service: / / </td> </tr> </table>	Did continuous monitoring equipment fail at any time this reporting month? No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No <i>Attach grab sample results and submit them with this form.</i>	Date continuous monitoring equipment failed: / / Date it was returned to service: / /
Did continuous monitoring equipment fail at any time this reporting month? No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No <i>Attach grab sample results and submit them with this form.</i>	Date continuous monitoring equipment failed: / / Date it was returned to service: / /		

Printed Name: MARCUS D HARSHMAN	Title: MAINTENANCE MANAGER	Operator Certification #:
Signature:	Phone #: (541) 247-6664	OR

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

Date: 04-02-2026

Small Groundwater System 41-91199
41-91199

Return by 10th of following month by either email dwp.dmce@odhsoha.oregon.gov ; fax 971-673-0458; or mail to Drinking Water Services, PO Box 14450, Portland, OR 97293-0450.

March 25, 2024