## State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

					WS ID# 4 1 91541	
Month/Year Aug 17027 Entry Po			oint: A	Required Minimum Residual 0.30 mg/L		
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L)		Notes
1		Well		0.5		
2		Well		0.6		
3		Well		0.6		
4		Well		0,6		
5		Well		0,6		
6		Well		0.6		
7		Well		0:6		
8		Well		0.6		
9		Well		0.3		
10		Well		0.5		
11		Well		0.5		
12		Well		03		
13		Well		015		
14		Well		0.5		
15		Well		0.3		
16		Well		0,5		
17		Well		0.5		
18		Well		0.5		
19		Well		0,5		
20		Well		0,5	-	
21		Well		0.5		
22		Well		Ois	-	
23 24		Well		O.S	-	
25		Well		013		
26		Well		0.5		
27		Well		0.5		
28		Well		015		
29		Well		0.5		
30		Well		0.5		
31		Well		013		
Was the chlorine residual ever less than the required minimum residual of 0.30 mg/L? Yes No						
If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No Attach those results and submit them with this form.			Did continuous monitoring equipment fail at any time this reporting month?  Yes  No		Date continuous monitoring equipment failed:	
			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No			1 1
			Attach grab sample results and submit them with this form.		1 1	
Printed Name: Eric Schaafsma			Title: Operator		Operator Certification #: 0-09353	
Signature	; _ Z ,	Delu/	Pho	ne #: (541)659-0700		OR
Date: 91612022					Small Gr	roundwater System

Return by 10<sup>th</sup> of following month by either email dwp.dmce@dhsoha.state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.