

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name **Rogue River Campground**

PWS ID# **41 91541**


Month/Year **June /2024** Entry Point: **A**

Required Minimum Residual **0.30 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1				
2				
3			0.5	
4			0.5	
5				
6			0.5	
7				
8				
9				
10			0.5	
11			0.5	
12				
13			0.5	
14				
15				
16				
17			0.5	
18			0.5	
19				
20			0.5	
21				
22				
23				
24			0.5	
25			0.5	
26				
27			0.5	
28				
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p align="center"><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
---	--	---

Printed Name: _____	Title: _____	Operator Certification #: _____
Signature: 	Phone #: ( ) _____	OR
Date: <b>7/3/24</b>		Small Groundwater System <input checked="" type="checkbox"/>

**Return by 10<sup>th</sup> of following month by either email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.**