State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

	n Name	Rogue River Camp	ground	PWS ID# 4 1 91541		
Month/Year www 1/2025 Entry F			Point: A	Required Minimum Residual 0.30 mg/L		
Date	Time	Source(s)) in use	Lowest free chlorine residual at entry point to distribution system (mg/l) -)	Notes
1	9:00	Well-GW		0.5		
2	9:00	Well-GW		05		
3	9:00	Well-GW		0.5		
4	9:00	Well-GW		0.5		
5	9:00	Well-GW		0.5		
6	9:00	Well-GW		0.5		
7	9:00	Well-GW		0.5		
8	9:00	Well-GW		05		
9	9:00	Well-GW		25		
10	9:00	Well-GW		65		
11	9:00	Well-GW		8/5	ce fill	dose tent
12	9:00	Well-GW		0.6	7 C + IC	o our - icur
13	9:00	Well-GW		25		
14	9:00	Well-GW		00		
15	9:00	Well-GW		R. S	_	
16	9:00	Well-GW		0.5		
17	9:00	Well-GW		70 6		
18	9:00	Well-GW		01)		
19	9:00	Well-GW		01)		
20	9:00	Well-GW		00	_	
21	9:00	Well-GW		0.5		
22	9:00	Well-GW		00		
23	9:00			GR		
24	9:00	Well-GW		010		
25		Well-GW		0.5		
	9:00	Well-GW		0.5		
26	9:00	Well-GW		0.5		
27	9:00	Well-GW		0.5		
28	9:00	Well-GW		0.5		
29	9:00	Well-GW		0.5		
30	9:00	Well-GW		0-5		
31	9:00	Well-GW		6.5		
Was the chlorine residual ever less than the required minimum residual of 0.30 mg/L? Yes You hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.						
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						
If yes, did you monitor every four hours until the residual returned to mg/L						Date continuous monitoring
as required?			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No No No Service:			
			Attach grab sample results and submit them with t		with this form.	1 1
Printed Name: Eric Schaafsma			Title: Operator		Operator Certification #: D-09353	
Signature			Phone #: (541)659-0700		OR	
ate:	119	175			Small Groundwater System	