State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name BEAR HOUNTAIN RV PARK PWS ID# 41-91544							
Month/	Year 😥	12023 Entry Po	int: We	e F	Required Minimum	Residual 1.2 mg/L	
Date	Time	Source(s) i		Lowest free chlorine residual at entry point distribution system (mg	to	Notes	
1	12:358	FAWCET IN W	eu House	1.46	,-,	3.25	
2	7:56 A	et .		1.48		2.25	
3	2.350	.35 P 11		1, 45		3.25	
4	1.15 P			47	=	7.2	
5	11:35A			1.42		3.25	
6	7:35A	LÍ		1,40		3.25	
7	2:458	re		1.42	-	3.25	
8	11:104			1.45		3.25	
9	1:358	54		1.41		7.25	
10	5:25P	V ⁴		1.44		3.25	
11	1:05P	١,		1.42		3.25	
12		21308		1.37		3.25	
13	8:55 A	6.		1.40		2.25 ANDED	
14	10:10A	11		1.35		3.25 CHIORINE	
15	12:35P	N		1-37		3.25	
16	8:304			ins		3.25	
17	1:107	**	the special property of the sp	(.35		2,25	
18	2:358			1.38		3,25	
19	4:458	r		1.41		3.25	
20	10:30A	^(c)		1.42		3,25	
21.	11:50A	CA .		1.38		3.25	
22	21358	L		1.39		325	
23	5.358	• •		1,40		3.25	
24	2:058	34		1,38		3.25	
25	11:251	11		(.4)		3.25	
26	1:308	+1		1.42		325	
27	7:50A	4	······································	1.39		2,25	
28	1:308	1,		, 37		3.25	
29	5:25€	[7	1,360			3.25	
30	11:35A	ч		1:38		3,25	
31	21308	"		1.360		3125	
Was the chlorine residual ever less than the required minimum residual of 1.2 mg/L? Yes No							
If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.							
GWS Serving 3,300 or Fewer GWS Serving I					g More Than 3,3	300	
If yes, did you monitor every four hours until the residual returned to mg/L as required? Yes No Attach those results and submit them with this form.			Did continuous monitoring equipment fail at any time this reporting month? Yes No		-	Date continuous monitoring equipment failed:	
			If yes, were grab samples collected every four hours un continuous monitoring equipment was returned to serving required?		four hours until the	1 1	
						Date it was returned to service:	
			Attach grab sample results and submit them v		em with this form.	with this form. / /	
Printed 1	Vame:	TOWN BOOK AMP	Operato	Operator Certification #:			
Signature: Phone #: (541) 278 -2400					0	OR	
					1		
Date: 11 / 2 / 2023					Siliali G	Small Groundwater System 🔀	