

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Restful Haven Health Club

PWS ID# 4 1 91609

Month/Year 04/2024

Entry Point: 2024WTP-A

Required Minimum Residual 1.0 mg/L



Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:30AM	Clubhouse Restroom	1.3	:Marshal Miller
2	8:30AM	Clubhouse Restroom	1.3	Marshall Miller
3	8:30AM	Clubhouse Restroom	1.3	Marshall Miller
4	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
5	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
6	9:00AM	Clubhouse Restroom	1.3	Marshall Miller
7	9:00AM	Clubhouse Restroom	1.3	Marshall Miller
8	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
9	9.30AM	Clubhouse Restroom	1.3	Marshall Miller
10	9.00AM	Clubhouse Restroom	1.3	Marshall Miller
11	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
12	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
13	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
14	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
15	9:00AM	Clubhouse Restroom	1.3	Marshall Miller
16	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
17	9:00AM	Clubhouse Restroom	1.3	Marshall Miller
18	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
19	9:00AM	Clubhouse Restroom	1.3	Marshall Miller
20	9:00AM	Clubhouse Restroom	1.3	Marshall Miller
21	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
22	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
23	9:00AM	Clubhouse Restroom	1.3	Marshall Miller
24	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
25	9.30AM	Clubhouse Restroom	1.3	Marshall Miller
26	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
27	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
28	9:00AM	Clubhouse Restroom	1.3	Marshall Miller
29	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
30	9:30AM	Clubhouse Restroom	1.3	Marshall Miller
31				

Was the chlorine residual ever less than the required minimum residual of 1.0 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach those results and submit them with this form.</i></p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p><i>Attach grab sample results and submit them with this form.</i></p>
<p>Date continuous monitoring equipment failed: _____ / _____ / _____</p> <p>Date it was returned to service: _____ / _____ / _____</p>	

<p>Printed Name: Kemper Bard</p> <p>Signature: </p> <p>Date: 05 / 02 / 2024</p>	<p>Title: MSR Host</p> <p>Phone #: (503) 647-2449</p>	<p>Operator Certification #: WTP-A</p> <p>OR</p> <p>Small Groundwater System <input type="checkbox"/></p>
---	---	---