State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

| 0 + N | | | | | | | |
|--|------------|--------------------|---|--|---------------------------------|----------------------------|--|
| System Name Restful Haven Health Club PWS ID# 4 1 91609 | | | | | | | |
| Month/Year Apr./2025 Entry Point: WTP-A Required Minimum Residual 1.0 mg/L | | | | | | | |
| Date | Time | Source(s) in use | | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes | | |
| 1 | 9:00AM | Clubhouse Restroom | | 1.3 | Marshall Miller | | |
| 2 | 9:30AM | Clubhouse Restroom | | 1.3 | MM | | |
| 3 | 9:30AM | Clubhouse Restroom | | 1.3 | Kemper Bard | | |
| 4 | 9:30AM | Clubhouse Restroom | | 1.3 | KB | | |
| 5 | 9:30AM | Clubhouse Restroom | | 1.3 | MM | | |
| 6 | 9:30AM | Clubhouse Restroom | | 1.3 | MM | | |
| 7 | 9:30AM | Clubhouse Restroom | | 1.3 | MM | | |
| 8 | 9:00AM | Clubhouse Restroom | | 1.3 | MM | | |
| 9 | 9:00AM | Clubhouse Restroor | n | 1.3 | MM | | |
| 10 | 9:00AM | Clubhouse Restroor | | 1.3 | MM | | |
| 11 | 9:00AM | Clubhouse Restroor | | 1.3 | MM | | |
| 12 | 8:30AM | Clubhouse Restroor | | 1.3 | MM | | |
| 13 | 9:30AM | Clubhouse Restroor | | 1.3 | MM | | |
| 14 | 8:30AM | Clubhouse Restroor | | 1.3 | MM | | |
| 15 | 8:30am | Clubhouse Restroor | | 1.3 | MM | | |
| 16 | 9:00AM | Clubhouse Restroor | | 1.3 | MM | | |
| 17 | 9:00AM | Clubhouse Restroor | | 1.3 | KB | | |
| 18 | 9:30AM | Clubhouse Restroor | | 1.3 | KB | | |
| 19 | 9:30AM | Clubhouse Restroor | | 1.3 | MM | | |
| 20 | 9:30AM | Clubhouse Restroom | | 1.3 | MM | | |
| 21 | 9:00AM | Clubhouse Restroor | | 1.3 | MM | | |
| 22 | 9:00AM | Clubhouse Restroom | | 1.3 | MM | | |
| 23 | 9:30AM | Clubhouse Restroom | | 1.3 | MM | | |
| 24 | 9:00AM | Clubhouse Restroom | | 1.3 | KB | | |
| 25 | 9:00AM | Clubhouse Restroom | | 1.3 | KB | | |
| 26 | 8:30AM | Clubhouse Restroor | | 1.3 | MM | | |
| 27 | 9:00AM | Clubhouse Restroom | | 1.3 | MM | | |
| 28 | 8:00AM | Clubhouse Restroom | | 1.3 | MM | | |
| 29 | 8:30AM | ClubHouse Restroom | | 1.3 | MM | | |
| 30 | 9:00AM | ClubHouse Restroom | | 1.3 | MM | | |
| 31 | | | | | <u> </u> | | |
| Was the chlorine residual ever less than the required minimum residual of 1.0 mg/L? Yes No If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day. | | | | | | | |
| GWS Serving 3,300 or Fewer GWS Serving More Than 3,300 | | | | | | 300 | |
| | | | Did continuous monitoring equipment fail at any | | · | Date continuous monitoring | |
| until the residual returned to mg/L as required? Yes No | | | | n? Yes No | y amo ano | equipment failed: | |
| | | | | <u> </u> | hours until the | 1 1 | |
| Attach those results and submit them with | | | If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as | | | Date it was returned to | |
| this form. | | | required? | ☐ Yes ☐ No | | service: | |
| | | | Attach grab sample results and submit them with | | ith this form. | 1 1 | |
| Printed N | Name: Kemp | er Bard | Title: Camp Host | | Operator Certification #: WTP-A | | |
| | · | | Dha | Phone #: (503) 647-2449 | | OR | |
| | | | | | | | |
| Date: Apr / 30 / 2025 Small Groundwater System | | | | | | roundwater System 🔲 | |