


**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

System Name Elk Lake Resort PWS ID# 41 91737
 Month/Year 10 / 24 Entry Point: Treated Site Required Residual 0.4 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system, 	Notes
1		<u>Well</u>	<u>Closed</u>	
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? ☐ Yes ☐ No
 If yes, what was the longest time period until the required level was restored? _____ Hours – If > 4 hours, Drinking Water ~~to~~ be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every ~~6~~ until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time in reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____ / _____ / _____

Date it was returned to service: _____ / _____ / _____

Printed Name: Pat Priore

Signature: [Signature]

Date: _____ / _____ / _____

Title: Owner

Phone #: (503) 501-8728

Operator Certification #: _____

OR

Small Groundwater System ☐