

April 2022

State of Oregon Drinking Water Program  
 Monthly Disinfection Report for Ground Water Systems

System Name Coast Marina			PWS ID# 41 91839	
Month/Year 4 2022			Entry Point: A	
			Required Minimum Residual 1.4 mg/L	
Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:45		1.4	
2	11:30		1.4	
3	1:22		1.4	
4	10:44		1.4	
5	10:3		1.4	
6	11:45		1.4	
7	11:30		1.4	
8	11:18		1.4	
9	11:45		1.4	
10	10:09		1.4	
11	9:34		1.4	
12	10:10		1.5	
13	10:17		1.4	
14	11:34		1.4	
15	11:21		1.4	
16	12:00		1.4	
17	10:41		1.4	
18	11:09		1.5	
19	9:22		1.4	
20	9:15		1.4	
21	11:30		1.4	
22	9:39		1.4	
23	11:15		1.4	
24	11:22		1.4	
25	11:15		1.4	
26	11:00		1.4	
27	11:10		1.4	
28	10:10		1.4	
29	10:29		1.4	
30	11:09		1.4	
31				

Was the chlorine residual ever less than the required minimum residual of mg/L?  Yes  No

If yes, what was the longest time period until the required level was restored? hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed:</p> <p>1 1</p> <p>Date it was returned to service:</p> <p>1 1</p>
--	---	---

Printed Name: Linda Klein Signature: Linda Klein Date: 5/11/2022	Title: Manager Phone #: (503) 541-590-5157	Operator Certification #: _____ OR Small Groundwater System <input checked="" type="checkbox"/>
--	---	---

December 19, 2012