

April 2023

State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name: Coast Marina			PWS ID# 41 91839		
Month/Year: 4/2023		Entry Point: A	Required Minimum Residual: 1.4 mg/L		

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:09	<i>R</i>	1.5	
2	11:00		1.5	
3	11:40		1.4	
4	10:10		1.4	
5	10:02		1.4	
6	8:30		1.4	
7	10:09		1.4	
8	11:00		1.4	
9	11:22		1.4	
10	10:34		1.4	
11	11:01		1.4	
12	2:00		1.4	
13	11:02		1.4	
14	10:29		1.4	
15	9:28		1.4	
16	11:02		1.4	
17	10:14		1.4	
18	11:01		1.4	
19	10:15		1.5	
20	10:09		1.4	
21	9:44		1.4	
22	9:21		1.4	
23	9:48		1.4	
24	9:41		1.4	
25	9:37		1.4	
26	9:50		1.4	
27	10:02		1.4	
28	9:49		1.4	
29	10:02		1.4	
30	10:07		1.4	
31				

Was the chlorine residual ever less than the required minimum residual of **1.4 mg/L**? Yes No

If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach these results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>
--	--	---

Printed Name: Lindy Klein Signature: _____ Date: 5/11/2023	Title: Manager Phone #: () _____ 541-590-5157	Operator Certification #: _____ OR Small Groundwater System <input checked="" type="checkbox"/>
--	--	---

December 19, 2012