

Dec 2023 New #

State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems

System Name: Coast Marina PWS ID: 01830  
 Month/Year: 1 Entry Point: A Required Minimum Residual: 0.7

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:27		1.4	
2	10:15		1.4	
3	10:41		1.4	
4	10:37		1.4	
5	10:41		1.3	
6	9:15		1.8	
7	10:29		1.2	
8	10:02		1.1	
9	10:38		0.9	
10	10:09		0.9	
11	10:22		0.8	
12	10:41		0.7	
13	10:20		0.7	
14	10:29		0.8	
15	10:39		1.0	
16	10:09		0.9	
17	10:21		0.8	
18	10:41		0.7	
19	10:44		0.8	
20	10:45		0.7	
21	10:10		0.7	
22	10:47		0.8	
23	9:41		0.7	
24	9:04		0.8	
25	10:47		0.8	
26	10:41		0.7	
27	10:30		0.7	
28	11:20		0.8	
29	11:07		0.7	
30	10:24		0.7	
31	10:41		0.8	

Was the chlorine residual ever less than its required minimum residual of mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? hours - if > 4 hours, Drinking Water Program to be notified by end of next business day.

**OWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to mg/L as required?  Yes  No  
 Attach these results and submit them with this form.

**OWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /  
 Date it was returned to service: / /

Printed Name: Lindy Klein  
 Signature: Lindy Klein  
 Date: 1/1/2024

Title: Manager  
 Phone #: ( ) 541-590-5157

Operator Certification #: OR  
 Small Groundwater System

December 19, 2012