

September 2024

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name
Month/Year

Coast Manna RV
9/2024

PWS ID# 41

Required Minimum Residual

0.7 mg/L

Entry Point:

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:21		1.0	
2	9:37		1.0	
3	9:09		1.0	
4	9:14		1.0	
5	9:41		1.0	
6	9:31		1.0	
7	9:41		1.0	
8	9:47		1.0	
9	9:44		1.0	
10	9:09		1.0	
11	9:59		1.0	
12	9:29		1.0	
13	9:41		1.0	
14	9:27		1.0	
15	9:51		1.0	
16	9:55		1.0	
17	9:37		1.0	
18	9:09		1.0	
19	9:44		1.0	
20	9:51		1.0	
21	9:47		1.0	
22	9:51		1.0	
23	9:47		1.0	
24	9:28		1.0	
25	9:41		1.0	
26	9:41		1.0	
27	9:40		1.0	
28	9:41		1.0	
29	9:09		1.0	
30	9:41		1.0	
31				

Was the chlorine residual ever less than the required minimum residual of mg/L? Yes No
If yes, what was the longest time period until the required level was restored? hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer If yes, did you monitor every four hours until the residual returned to mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300 Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / / Date it was returned to service: / /</p>
--	---	--

Printed Name: Linda Klein Title: Manager Operator Certification #: _____
 Signature: Linda Klein Phone #: () _____ OR _____
 Date: 10/1/2024 541-590-3157 Small Groundwater System

Return by 10th of following month by either email dwp.dmce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.