

# FEBRUARY 2025

## Monthly Disinfection Report for Ground Water Systems

System Name:   PWS ID# 41  
 Month/Year:   Entry Point:   Required Minimum Residual: **0.7** mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0800		1.21	1 cup
2	0800		1.25	1 cup
3	0800		1.20	1 cup
4	0800		1.28	1 cup
5	0800		1.34	
6	0800		1.39	
7	0900		1.43	
8	0800		1.23	1 cup
9	0800		1.53	
10	0800		1.53	
11	0800		1.19	1 cup
12	0800		1.41	
13	0800		1.38	1 cup
14	0800		1.27	1 cup
15	0800		1.56	
16	0800		1.50	
17	0800		1.59	
18	0800		1.33	
19	0800		1.53	
20	0800		1.42	
21	0800		1.39	
22	0800		1.36	
23	0800		1.36	
24	0800		1.32	
25	0800		1.22	1/2 cup
26	0800		1.03	1 cup
27	0800		1.83	1.5 cup
28			1.00	1 cup
29				
30				
31				

Was the chlorine residual ever less than the required minimum residual of .7 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required?  Yes  No  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_  
 Date it was returned to service: \_\_\_\_\_

Printed Name: LYNN KORNCO  
 Signature: *[Handwritten Signature]*  
 Date: 02/28/2025

Title: COAST MARINA MANAGER  
 Phone #: 970 783-8199

Operator Certification #: \_\_\_\_\_  
 OR  
 Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us); fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.