

JULY 2025

State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

 System Name
 Month/Year

7/2025

Entry Point:

 COAST MARINA
 91839

PWS ID# 41

Required Minimum Residual

 0.7
 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0710		1.71	
2	0720		1.70	
3	0730		1.61	
4	0740		1.62	
5	0750		1.71	
6	0800		1.82	
7	0810		1.05	
8	0820		1.37	1 cup = water
9	0830		1.02	
10	0840		1.70	1 cup
11	0850		1.76	1 cup
12	0900		1.40	1 cup
13	0910		1.91	1 cup
14	0920		1.84	1 cup
15	0930		1.70	1 cup
16	0940		1.86	
17	0950		1.07	
18	1000		1.06	1 cup
19	1010		1.50	
20	1020		1.75	
21	1030		1.85	
22	1040		1.09	
23	1050		1.20	
24	1100		1.70	
25	1110		1.70	1 cup
26	1120		1.72	1 cup
27	1130		1.72	
28	1140		1.82	
29	1150		1.74	1 cup
30	1200		1.72	1 cup
31	1210		1.41	

 Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

 If yes, did you monitor every four hours until the residual returned to mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

 Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No

 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

 / /
 Date it was returned to service:

/ /

 Printed Name: Lynn Romero
 Signature: [Signature]
 Date: 7/31/2025

 Title: MANAGER
 Phone #: ()
 Cell: 940 7838190

Operator Certification #:

OR

 Small Groundwater System: ☒

 Return by 10th of following month by either email gws.dmrce@state.or.us; fax 971-673-0694; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019