

AUGUST 2025

State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name
Month/Year

COAST MARINA

Entry Point: 91839

PWS ID# 41

Required Minimum Residual

0.7
mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	0700		.94	1 cup
2	0700		1.2	
3	0700		1.35	
4	0700		1.02	
5	0700		1.13	
6	0700		1.11	1
7	0700		1.53	
8	0700		1.50	
9	0700		1.25	
10	0700		.84	1 cup
11	0700		1.00	
12	0700		1.00	
13	0700		.91	
14	0700		1.20	
15	0700		1.24	
16	0700		1.80	
17	0700		1.00	
18	0700		1.03	
19	0700		1.04	2 cup
20	0700		1.00	
21	0700		1.00	
22	0700		.97	2 cup
23	0700		1.16	
24	0700		1.20	
25	0700		1.75	1 cup
26	0700		1.77	1 cup
27	0700		.80	
28	0700		1.00	
29	0700		1.56	
30	0700		1.55	
31	0700			

Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored?
notified by end of next business day.

hours - If > 4 hours, Drinking Water Program to be

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /
Date it was returned to service:

/ /

Printed Name: LYNN ROMERO

Signature:

Date: 8/31/2025

Title: Manager

Phone #: ()

Operator Certification #:

OR

Small Groundwater System ☐

Return by 10th of following month by either email dwp.dnce@state.or.us; fax 971-673-0684;
or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019