

March 2022

State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems

System Name Coast Marina			PWS ID# 41 91839		
Month/Year 03/2022			Entry Point: A		
			Required Minimum Residual 1.4 mg/L		
Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes	
1	11:30		1.4		
2	11:59		1.4		
3	10:25		1.4		
4	11:15		1.4		
5	11:15		1.4		
6	12:25		1.4		
7	11:41		1.4		
8	12:29		1.4		
9	12:34		1.4		
10	12:50		1.4		
11	12:53		1.4		
12	12:10		1.4		
13	12:14		1.4		
14	11:19		1.4		
15	12:10		1.4		
16	11:41		1.4		
17	11:30		1.4		
18	10:41		1.4		
19	11:30		1.4		
20	10:12		1.4		
21	10:22		1.4		
22	10:39		1.4		
23	11:25		1.4		
24	11:30		1.4		
25	11:38		1.4		
26	11:08		1.4		
27	11:59		1.4		
28	10:04		1.5		
29	11:37		1.4		
30	11:40		1.4		
31	11:57		1.4		
Was the chlorine residual ever less than the required minimum residual of mg/L? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, what was the longest time period until the required level was restored? hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.					
<b>GWS Serving 3,300 or Fewer</b> If yes, did you monitor every four hours until the residual returned to mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach those results and submit them with this form.		<b>GWS Serving More Than 3,300</b> Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach grab sample results and submit them with this form.		Date continuous monitoring equipment failed: / / Date it was returned to service: / /	
Printed Name: Linda Klein Signature: Linda Klein Date: 4/11/2022		Title: Manager Phone #: ( ) Cell: 541-590-5157		Operator Certification #: OR Small Groundwater System <input checked="" type="checkbox"/>	

December 19, 2012