

# August 2023

State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems

System Name: <b>Coast Marine</b>	PWS ID# <b>41 91839</b>
Month/Year: <b>8 2023</b> Entry Point: <b>A</b>	Required Minimum Residual: <b>1.4 mg/L</b>

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:12		1.4	
2	10:35		1.4	
3	10:10		1.4	
4	10:15		1.4	
5	10:10		1.4	
6	10:10		1.3	
7	10:41		1.3	
8	10:09		1.4	
9	10:39		1.5	
10	10:29		1.4	
11	10:48		1.5	
12	10:14		1.5	
13	10:22		1.4	
14	10:09		1.4	
15	10:00		1.4	
18	9:24		1.3	
17	9:14		1.4	
18	9:49		1.4	
19	9:40		1.4	
20	9:14		1.4	
21	9:15		1.5	
22	9:15		1.5	
23	9:40		1.4	
24	9:21		1.4	
25	9:19		1.4	
26	10:05		1.4	
27	9:44		1.4	
28	9:31		1.4	
29	9:44		1.4	
30	9:40		1.5	
31	9:37		1.4	

Was the chlorine residual ever less than the required minimum residual of mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? hours - if > 4 hours, Drinking Water Program to be notified by end of next business day

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to <u>mg/L</u> as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: <u>  /  /  </u></p> <p>Date it was returned to service: <u>  /  /  </u></p>
--	--	---

Printed Name: <u>Lynda Klein</u>	Title: <u>Manager</u>	Operator Certification #: <u>  </u>
Signature: <u>Lynda Klein</u>	Phone #: <u>( ) 541-590-5157</u>	OR
Date: <u>8/31/2023</u>		Small Groundwater System <input checked="" type="checkbox"/>

December 19, 2012