

June 2024

State of Oregon Drinking Water Program Monthly Chlorination Report for Ground Water Systems

System Name: Coast Marina PWS ID: 01090
 Month/Year: 6/2024 Entry Point: A Required Minimum Residual: 1.70

Date	Time	Residual(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	9:41		1.1	
2	9:44		1.1	
3	9:29		1.1	
4	9:38		1.1	
5	9:21		1.1	
6	10:22		1.0	
7	9:41		1.0	
8	9:01		1.0	
9	9:21		1.0	
10	9:34		1.0	
11	9:41		1.0	
12	9:45		1.0	
13	9:22		1.0	
14	9:25		1.0	
15	9:13		1.0	
16	9:41		1.1	
17	9:29		1.0	
18	9:51		1.0	
19	9:31		1.0	
20	9:22		1.0	
21	9:41		1.1	
22	9:27		1.1	
23	9:36		1.1	
24	9:29		1.0	
25	9:01		1.0	
26	8:45		1.0	
27	9:47		1.0	
28	9:47		1.0	
29	9:01		1.0	
30	9:09		1.0	
31				

Was the chlorine residual ever less than the required minimum residual of 1.70 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? None - if > 4 hours, Drinking Water Program to be notified for cost of rapid response cost.

ORWA Serving 3,000 or Fewer
 If you, did you monitor every four hours until the residual returned to mg/L, as required? Yes No
 Attach these results and submit them with this form.

ORWA Serving More Than 3,000
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: 1/1
 Date it was returned to service: 1/1

Printed Name: Linda Klen Title: Manager Operator Certification #: 07
 Signature: [Signature] Phone #: 541-340-5157 Facility Groundwater System: 4
 Date: 7/11/2024

December 19, 2017