

Brand@

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name RIVER PARK RV RESORT PWS ID# 4191911
 Month/Year 5/23 Entry Point: OFFICE Required Minimum Residual 1.0 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:00	OFFICE	1.8	
2	10:00		1.7	
3	10:00		1.6	
4	10:00		1.8	
5	10:00		1.5	
6	10:00		1.7	
7	10:00		1.6	
8	10:00		1.8	
9	10:00		1.0	
10	10:00		1.4	
11	10:00		1.4	
12	10:00		1.0	
13	10:00		1.1	
14	10:00		1.09	
15	10:00		1.09	
16	10:00		1.08	
17	10:00		1.09	
18	10:00		1.06	
19	10:00		1.04	
20	10:00		1.05	
21	10:00		1.06	
22	10:00		1.06	1.06
23	10:00		1.10	
24	10:00		1.11	
25	10:00		1.09	
26	10:00		1.09	
27	10:00		1.10	
28	10:00		1.11	
29	10:00		1.10	
30	10:00		1.11	
31	10:00		1.12	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L? Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / / Date it was returned to service: / /</p>
---	---	---

Printed Name: Donna Logan Title: OWNER Operator Certification #:
 Signature: D Logan Phone #: 541-295-1289

12

Jul
T W
4 5
1 12
8 19
5 26

S
1