

### State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Name RIVERPARK RV RESORT

PWS ID# 4191911

Month/Year 04/21 Entry Point: OFFICCA

Required Minimum Residual 1.0 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:00	OFFICCA	1.32	
2	10:00		1.33	
3	10:00		1.33	
4	10:00		1.32	
5	10:00		1.31	
6	10:00		1.31	
7	10:00		1.32	
8	10:00		1.56	
9	10:00		1.50	
10	10:00		1.50	
11	10:00		1.48	
12	10:00		1.48	
13	10:00		1.51	
14	10:00		1.50	
15	10:00		1.49	
16	10:00		1.48	
17	10:00		1.15	
18	10:00		1.17	
19	10:00		1.15	
20	10:00		<del>1.18</del> 1.18	
21	10:00		1.17	
22	10:00		1.16	
23	10:00		1.16	
24	10:00		1.16	
25	10:00		1.16	
26	10:00		1.16	
27	10:00		1.16	
28	10:00		1.15	
29	10:00		1.15	
30	10:00		1.17	

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

#### GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L?

Attach those results and submit them with this form.

#### GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /

Date it was returned to service: / /

Printed Name: Donna Logan

Title: OWNER

Operator Certification #:

Signature: [Signature]

Phone #: 541-295-1267