

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Days Creek

PWS ID# 41 92101

Month/Year 7 125 Entry Point: A

Required Minimum Residual 1.0 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	1530		2.5	
2	0815		2.2	
3	0710		2.3	
4				
5				
6				NO School
7	1530		2.2	
8	1530		2.05	
9	0700		2.1	
10	1100		1.9	
11	0730		2.7	
12				
13				NO School
14	0645		1.81	
15	0705		2	
16	0700		2.1	
17	1430		2.15	
18				
19				NO School
20				
21	0715		2.05	
22	0700		2.13	
23	0700		2.2	
24	0700		2.05	
25	0700		2	
26				
27				NO School
28	0700		2.15	
29	0645		2.13	
30	0700		2.1	
31	1500		2.11	

Was the chlorine residual ever less than the required minimum residual of _____ mg/L? ☐ Yes ☐ No

If yes, what was the longest-time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____

Date it was returned to service: _____

Printed Name: El Jenkins

Title: Water Operator

Operator Certification # 296386

Signature: El Jenkins

Phone #: (911) 825-3296

OR

Date: 7 13 2025

Small Groundwater System ☐