

| Date | Time | Source(s) in use | Lowest free chlorine residual at entry point to distribution system (mg/L) | Notes |
|------|------|------------------|----------------------------------------------------------------------------|-------|
| 1    | 8:15 | ENTRY POINT      | 0.9                                                                        |       |
| 2    | 7:45 | ENTRY POINT      | 0.9                                                                        |       |
| 3    | 8:25 | ENTRY POINT      | 0.8                                                                        |       |
| 4    | 7:19 | ENTRY POINT      | 0.8                                                                        |       |
| 5    | 6:52 | ENTRY POINT      | 0.9                                                                        |       |
| 6    | 6:18 | ENTRY POINT      | 0.9                                                                        |       |
| 7    | 7:48 | ENTRY POINT      | 0.8                                                                        |       |
| 8    | 6:31 | ENTRY POINT      | 0.9                                                                        |       |
| 9    | 7:55 | ENTRY POINT      | 0.9                                                                        |       |
| 10   | 8:30 | ENTRY POINT      | 0.8                                                                        |       |
| 11   | 7:31 | ENTRY POINT      | 0.9                                                                        |       |
| 12   | 6:07 | ENTRY POINT      | 0.8                                                                        |       |
| 13   | 6:26 | ENTRY POINT      | 0.7                                                                        |       |
| 14   | 7:15 | ENTRY POINT      | 0.7                                                                        |       |
| 15   | 7:42 | ENTRY POINT      | 0.8                                                                        |       |
| 16   | 8:55 | ENTRY POINT      | 0.9                                                                        |       |
| 17   | 7:32 | ENTRY POINT      | 0.8                                                                        |       |
| 18   | 9:26 | ENTRY POINT      | 0.8                                                                        |       |
| 19   | 6:53 | ENTRY POINT      | 0.9                                                                        |       |
| 20   | 7:12 | ENTRY POINT      | 0.9                                                                        |       |
| 21   | 8:19 | ENTRY POINT      | 0.7                                                                        |       |
| 22   | 7:55 | ENTRY POINT      | 0.8                                                                        |       |
| 23   | 8:21 | ENTRY POINT      | 0.8                                                                        |       |
| 24   | 7:26 | ENTRY POINT      | 0.8                                                                        |       |
| 25   | 6:30 | ENTRY POINT      | 0.8                                                                        |       |
| 26   | 7:35 | ENTRY POINT      | 0.8                                                                        |       |
| 27   | 6:21 | ENTRY POINT      | 0.7                                                                        |       |
| 28   | 7:55 | ENTRY POINT      | 0.7                                                                        |       |
| 29   | 6:42 | ENTRY POINT      | 0.7                                                                        |       |
| 30   | 8:05 | ENTRY POINT      | 0.8                                                                        |       |
| 31   | 8:55 | ENTRY POINT      | 0.8                                                                        |       |

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? ☐ Yes ☐ No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required? ☐ Yes ☐ No  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☒ No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_  
 Date it was returned to service: \_\_\_\_\_

Printed Name: Bruce Elder  
 Signature: [Signature]  
 Date: 1/31/25

Title: Manager  
 Phone #: (541) 371-2025

Operator Certification #: \_\_\_\_\_  
 OR  
 Small Groundwater System ☐