

System Name Martin Adobe Home ParkPWS ID# 4193484Month/Year 9 125 Entry Point: wellRequired Minimum Residual 2.1 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:00	well	2.1	
2	4:30	well	1.9	
3	3:30	well	2.1	
4	6:00		2.1	
5	2:30	well	2.2	
6	6:00	well	1.9	
7	1:00	well	1.9	
8	3:00	well	1.9	
9	4:00	well	1.9	
10	1:30	well	1.8	
11	5:30	well	1.8	
12	6:00	well	2.2	
13	5:30	well	2.1	
14	4:00		2.2	
15	1:30	well	2.0	
16	4:30	well	1.8	
17	6:30	well	2.0	
18	4:00	well	1.9	
19	4:30	well	1.9	
20	3:30	well	1.9	
21	5:30	well	1.8	
22	4:30	well	1.9	
23	5:30	well	1.8	
24	4:30	well	2.2	
25	5:30	well	1.8	
26	5:30	well	2.2	
27	4:00	well	2.1	
28	4:30	well	2.1	
29	5:00	well	1.8	
30	5:00	well	1.8	
31				

Was the chlorine residual ever less than the required minimum residual of 2.1 mg/L? ☐ Yes ☒ No

If yes, what was the longest time period until the required level was restored? _____ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or FewerIf yes, did you monitor every four hours until the residual returned to _____ mg/L as required? ☐ Yes ☐ No

Attach those results and submit them with this form.

GWS Serving More Than 3,300Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☐ NoIf yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☐ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: _____

Date it was returned to service: _____

Printed Name: Connie EatonTitle: Owner

Operator Certification #:

Signature: Connie EatonPhone #: (541) 474-5036

OR

Date: 9 130 12025Small Groundwater System ☒Return by 10th of following month by either email dwp.dmce@odhsoha.oregon.gov; fax

or mail to Drinking Water Services, PO Box 14500, Portland, OR 97224-0500

Revised 12/2011