

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name Troy Resort – Wenaha Bar & Grill PWS ID# 41 93931  
 Month/Year 3, 25 Entry Point: EP-B for Well #2 Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:30	Well #2	0.8	
2	9:30	Well #2	0.8	26 gal Solution
3		Well #2	(closed)	
4		Well #2	(closed)	
5		Well #2	(closed)	
6	10:30	Well #2	0.8	
7	11:00	Well #2	0.8	
8	9:30	Well #2	0.8	
9	10:30	Well #2	0.8	
10		Well #2	(closed)	
11		Well #2	(closed)	
12		Well #2	(closed)	
13	8:00	Well #2	0.8	
14	10:30	Well #2	0.8	
15	8:00	Well #2	0.8	
16	9:30	Well #2	0.8	18 gal Solution
17		Well #2	(closed)	
18		Well #2	(closed)	
19		Well #2	(closed)	
20	11:30	Well #2	0.8	
21	10:00	Well #2	0.8	
22	9:30	Well #2	0.8	
23	7:30	Well #2	0.8	
24		Well #2	(closed)	
25		Well #2	(closed)	
26		Well #2	(closed)	
27	8:30	Well #2	0.8	
28	10:30	Well #2	0.8	
29	7:00	Well #2	0.8	12 gal Solution
30	9:30	Well #2	0.8	
31		Well #2	(closed)	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? ☐ Yes ☒ No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required? ☐ Yes ☒ No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? ☐ Yes ☒ No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: \_\_\_\_\_

Date it was returned to service: \_\_\_\_\_

Printed Name: Douglas P. Withers Title: Manager  
 Signature: Douglas P. Withers Phone #: (541) 828-7773  
 Date: 4/3/25

Operator Certification #: \_\_\_\_\_

Small Groundwater System ☐