

**State of Oregon Drinking Water Services  
Monthly Disinfection Report for Ground Water Systems**

System Name Troy Resort

PWS ID# 41 93931

Month/Year 3 12 23 Entry Point: EP-B for Well #2

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	Am	(Close Well #2)	opening after seasonal shutdown	
2	7:00	Well #2	1.2	
3	8:30	Well #2	1.2	
4	9:00	Well #2	1.0	
5	10:30	Well #2		21 gal solution
6		Well #2	closed	
7		Well #2	"	
8		Well #2	closed	
9	8:30	Well #2	1.0	
10	10:00	Well #2	1.2	
11	7:30	Well #2	1.2	
12	9:00	Well #2	1.2	
13		Well #2	closed	
14		Well #2	"	
15		Well #2	closed	
16	7:30	Well #2	1.0	
17	11:30	Well #2	1.2	19 gal solution
18	10:45	Well #2	1.2	
19	11:15	Well #2	1.2	
20		Well #2	closed	
21		Well #2	closed	
22		Well #2	closed	
23	11:30	Well #2	1.2	
24	10:30	Well #2	1.2	
25	9:30	Well #2	1.2	18 gal solution
26	8:00	Well #2	1.2	
27		Well #2	closed	
28		Well #2	"	
29		Well #2	closed	
30	11:00	Well #2	1.2	
31	10:30	Well #2	1.2	15 gal solution

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours - if > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required?  Yes  No  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 Date continuous monitoring equipment failed: \_\_\_\_\_  
 If yes, were grab samples collected every two hours until the continuous monitoring equipment was returned to service as required?  Yes  No  
 Date it was returned to service: \_\_\_\_\_  
 Attach grab sample results and submit them with this form.

Printed Name: Doug Witherrite  
 Signature: Doug Witherrite  
 Date: 3 12 23

Title: Manager  
 Phone #: (541) 828-7773

Operator Certification #: n/a  
 Small Groundwater System