

**State of Oregon Drinking Water Services  
Monthly Disinfection Report for Ground Water Systems**

System Name Troy Resort

PWS ID# 41 93931

Month/Year 4/23 Entry Point: EP-B for Well #2

Required Minimum Residual 0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:30 Am	Well #2	1.2	12 gal Solution cut down on Solution Injection
2	8:30	Well #2	1.2	
3		Well #2	closed	
4		Well #2		
5		Well #2		
6	8:30	Well #2	0.8	
7	10:00	Well #2	0.8	
8	11:30	Well #2	0.8	
9	9:00	Well #2	0.8	
10		Well #2	closed	
11		Well #2		
12		Well #2		
13	7:30	Well #2	0.8	
14	9:30	Well #2	0.8	
15	10:00	Well #2	0.8	
16	11:00	Well #2	0.8	10 gal Solution
17		Well #2	closed	
18		Well #2		
19		Well #2		
20	8:30	Well #2	0.8	
21	9:00	Well #2	0.8	
22	10:30	Well #2	0.8	
23	11:00	Well #2	0.8	
24		Well #2	closed	
25		Well #2		
26		Well #2		
27	11:30	Well #2	0.8	ADD solution to 21 gal
28	10:00	Well #2	0.8	
29	8:30	Well #2	0.8	
30	9:00	Well #2	0.8	
31		Well #2		

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ Hours - if > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required?  Yes  No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every 4 hours until the continuous monitoring equipment was returned to service as required?  Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

\_\_\_\_/\_\_\_\_/\_\_\_\_  
Date it was returned to service:

\_\_\_\_/\_\_\_\_/\_\_\_\_

Printed Name: Doug Withervit

Title: Manager

Signature: Doug Withervit

Phone #: (541) 828-7773

Date: 5/8/23

Operator Certification #: n/a

Small Groundwater System