

State of Oregon Drinking Water Program
 Monthly Disinfection Report for Ground Water Systems

Lost Valley Educational Center

PWS ID# 41 94011

System Name
 Month/Year

September 2021

Entry Point: A

Lodge Sink

Required Minimum Residual

0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	2:40	Lodge Sink	.2	fill SD
2	4:00	" "	.5	SD
3	3:10	" "	.5	SD
4	2:30	" "	.5	SD
5	4:00	" "	.4	SD
6	2:10	" "	.4	SD
7	3:30	" "	.3	SD
8	4:00	" "	.4	SD
9	11:50	" "	.3	SD
10	12:00	" "	.3	SD
11	3:00	" "	.3	SD
12	5:10	" "	.3	SD
13	6:00	" "	.3	SD
14	5:30	" "	.3	SD
15	4:00	" "	.3	SD
16	2:00	" "	.3	SD
17	1:30	" "	.3	SD
18	10:00	" "	.3	SD
19	11:30	" "	.3	SD
20	12:00	" "	.3	SD
21	1:30	" "	.3	SD
22	11:30	" "	.2	SD fill tank
23	12	" "	.4	SD
24	1:05	" "	.3	SD
25	2:30	" "	.4	SD
26	1:30	" "	.4	SD
27	12:45	" "	.3	SD
28	11:30	" "	.3	SD
29	12	" "	.3	SD
30	11:45	" "	.3	SD
31				

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No

If yes, what was the longest time period until the required level was realized? 0 hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to 0.2 mg/L as required? Yes No
 Attach those results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /
 Date it was returned to service: / /