

State of Oregon Drinking Water Program  
 Monthly Disinfection Report for Ground Water Systems

System Name **LOST VALLEY CENTER** PWS ID# 41  
 Month/Year **12/24** Entry Point: **A** Required Minimum Residual **.2** mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	3:00	Building 15	1.3	SIF + SALT
2	1:45	" "	1.3	SIF
3	3:20	" "	1.3	SIF + SALT
4	1:15	" "	1.3	SIF + SALT
5	11:35	" "	1.3	SIF + SALT
6	2:30	" "	1.3	SIF
7	3:30	" "	1.3	SIF
8	1:45	" "	1.4	SIF + SALT
9	2:30	" "	1.4	SIF
10	12:30	" "	1.4	SIF + 1 BAG
11	11:30	" "	1.4	SIF
12	2:30	" "	1.4	SIF + 1 BAG
13	3:00	" "	1.3	SIF
14	2:45	" "	1.3	SIF + 3/4 BAG
15	3:20	" "	1.4	SIF + 1/4 BAG
16	3:00	" "	1.4	SIF + 1/4 BAG
17	11:50	" "	1.4	SIF
18	2:00	" "	1.4	SIF 3/4 bag
19	2:05	" "	1.3	SIF
20	3:20	" "	1.4	SIF 1/2 bag
21	6:00	" "	1.3	SIF
22	4:00	" "	1.4	SIF 1 bag
23	2:30	" "	1.4	SIF 1 Bag
24	11:15	" "	1.4	SIF
25	8:00	" "	1.5	SIF
26	6:00	" "	1.3	SIF 1 Bag
27	4:15	" "	1.3	SIF
28	11:00	" "	1.4	SIF
29	2:00	" "	1.4	SIF 1 BAG
30	1:30	" "	1.4	SIF
31	11:45	" "	1.4	SIF

Was the chlorine residual ever less than the required minimum residual of **mg/L?**  Yes  No  
 If yes, what was the longest time period until the required level was restored? **hours -**  > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**  
 If yes, did you monitor every four hours until the residual returned to **mg/L** as required?  Yes  No  
 Attach those results and submit them with this form.

**GWS Serving More Than 3,300**  
 Did continuous monitoring equipment fail at any time this reporting month?  Yes  No  
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No  
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: **/ /**  
 Date it was returned to service: **/ /**

Printed Name: **SHARON LEE FRANTZ** Title: **MONITOR**  
 Signature: *Sharon Lee Frantz* Phone #: **(503) 354-7591**  
 Date: **1/3/2025**

Operator Certification # **GR**  
 Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dwp.dms@state.or.us](mailto:dwp.dms@state.or.us), fax 971-672-0694, or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.