

Christal Rainey Sec. *Christal Rainey* 541 826 5421

State of Oregon Drinking Water Program
 Monthly Disinfection Report for Ground Water Systems

System Name **RAINEYS CORNER** PWS ID# 41 **94386**
 Month/Year **9/22** WTP-A Req'd Min Residual mg/L **0.4**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:45 AM	ulticlit sink	.40	
2	7:55 AM		.40	
3	7:30 AM		.40	
4	6:05 AM		.40	
5	6:10 AM		.40	
6	7:30 AM		.41	
7	7:45 AM		.41	
8	6:15 AM		.40	
9	6:30 AM		.40	
10	8:15 AM		.41	
11	7:00 AM		.40	
12	7:20 AM		.40	
13	6:40 AM		.40	
14	6:30 AM		.40	
15	6:45 AM		.40	
16	7:00 AM		.40	
17	6:45 AM		.40	
18	7:10 AM		.40	
19	7:00 AM		.40	
20	7:15 AM		.40	
21	6:50 AM		.40	
22	7:20 AM		.40	
23	6:30 AM		.40	
24	7:20 AM		.40	
25	7:00 AM		.40	
26	6:45 AM		.40	
27	6:40 AM		.40	
28	6:45 AM		.41	
29	7:45 AM		.41	
30	7:35 AM		.41	
31				

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
	<p>Date continuous monitoring equipment failed: / /</p> <p>Date it was returned to service: / /</p>