

Christal Rainey 541 826 5421

Secretary Christal Rainey

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name		RAINEYS CORNER		PWS ID# 41	94386
Month/Year		21 25		WTP-A	Req'd Min Residual mg/L 0.4
Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes	
1	7:10 AM	utility sink	40		
2	6:40 AM		40		
3	6:20 AM		40		
4	6:15 AM		40		
5	7:00 AM		40		
6	6:30 AM		41		
7	7:00 AM		40		
8	6:30 AM		40		
9	7:45 AM		40		
10	6:50 AM		40		
11	6:10 AM		40		
12	6:15 AM		40		
13	7:30 AM		41		
14	8:00 AM		41		
15	6:00 AM		40		
16	7:05 AM		40		
17	9:00 AM		41		
18	8:35 AM		40		
19	7:30 AM		40		
20	6:15 AM		40		
21	7:50 AM		40		
22	6:20 AM		40		
23	8:30 AM		40		
24	6:15 AM		40		
25	7:15 AM		40		
26	6:20 AM		40		
27	6:30 AM		40		
28	6:40 AM		40		
29					
30					
31					

Was the chlorine residual ever less than the required minimum residual of 0.4 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? hours - if > 4 hours. Drinking Water Program to be notified by end of next business day.

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to mg/L as required?
 Yes No
 Attach those results and submit them with this form

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No
 Attach grab sample results and submit them with this form

Date continuous monitoring equipment failed: / /
 Date it was returned to service: / /