

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name **Ray's food place #71**

PWS ID# **41 94437**


Month/Year **June 2023** Entry Point: **A**

Required Minimum Residual **.5 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:26	A	2.0	
2	7:55	A	1.6	
3	7:39	A	2.4	
4	7:26	A	2.8	
5	8:29	A	2.0	
6	7:43	A	1.8	
7	8:48	A	1.6	
8	7:45	A	1.6	
9	7:38	A	1.8	
10	7:37	A	2.0	
11	7:52	A	1.6	
12	7:41	A	1.2	
13	8:14	A	1.6	
14	7:46	A	1.6	
15	7:45	A	1.6	
16	7:38	A	1.6	
17	9:43	A	1.2	
18	7:32	A	1.6	
19	7:35	A	1.6	
20	7:46	A	1.6	
21	7:26	A	1.6	
22	9:00	A	1.6	
23	8:31	A	3.0	
24	7:26	A	3.0	
25	7:45	A	3.0	
26	7:29	A	3.0	
27	8:14	A	3.0	
28	9:00	A	2.8	
29	8:10	A	1.6	
30	7:24	A	2.4	
31				

Was the chlorine residual ever less than the required minimum residual of .5 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Date continuous monitoring equipment failed: / /</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Date it was returned to service: / /</p> <p>Attach grab sample results and submit them with this form.</p>
--	--

Printed Name: **Proebe Summers** Title: **Produce Manager** Operator Certification #: _____
 Signature:  Phone #: **(541) 597-4344** OR
 Date: **6/30/2023** Small Groundwater System