

State of Oregon Drinking Water Program  
**Monthly Disinfection Report for Ground Water Systems**

System Name **Ray's food place #71**

PWS ID# **41 94437**

Month/Year **Nov / 2023** Entry Point: **A**

Required Minimum Residual **.5 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	7:14	A	.8	
2	7:22	A	.8	
3	8:15	A	.8	
4	7:31	A	.6	
5	7:34	A	.6	
6	7:21	A	.6	
7	7:41	A	.6	
8	7:25	A	.6	
9	8:05	A	.6	
10	7:20	A	.6	
11	7:42	A	1.4	
12	7:27	A	1.0	
13	7:24	A	1.0	
14	7:22	A	1.0	
15	7:32	A	1.0	
16	8:15	A	1.0	
17	10:10	A	1.0	
18	7:22	A	1.6	
19	7:48	A	1.2	
20	7:52	A	1.2	
21	8:15	A	1.0	
22	12:15	A	1.0	
23	6:14	A	1.8	
24	7:34	A	2.0	
25	7:18	A	3.0	
26	7:21	A	2.8	
27	7:29	A	2.8	
28	7:42	A	2.8	
29	7:51	A	2.8	
30	7:24	A	2.6	
31				

Was the chlorine residual ever less than the required minimum residual of .5 mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p><b>GWS Serving 3,300 or Fewer</b></p> <p>If yes, did you monitor every four hours until the residual returned to _____ mg/L as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p><b>GWS Serving More Than 3,300</b></p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: _____ / _____ / _____</p> <p>Date it was returned to service: _____ / _____ / _____</p>
--	--	---

Printed Name: Proeoe Summers Title: Produce Manager Operator Certification #: \_\_\_\_\_  
 Signature: [Signature] Phone #: (541) 359-1442 OR  
 Date: 11/30/2023 Small Groundwater System