

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name Mountain Man RV Park



PWS ID# 4 1 94512

Month/Year _01/2022

Entry Point: PUmp house EP-B

Required Minimum Residual 1.0 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	10:00		1.5	
2	9:30		1.5	
3	9:00		1.4	
4	11:00		1.4	Added 80 oz CL 40 gal H2O
5	9:00		1.4	
6	9:30		1.5	
7	9:30		1.6	
8	9:00		1.6	
9	9:00		1.7	
10	9:00		1.8	
11	9:00		1.7	
12	9:00		1.6	
13	9:00		1.6	
14	9:30		1.5	
15	9:00		1.5	
16	9:00		1.4	
17	9:00		1.4	
18	10:00		1.4	Added 80 oz CL 40 gal H2O
19	9:00		1.4	
20	9:00		1.5	
21	9:00		1.6	
22	9:30		1.6	
23	9:30		1.7	
24	9:00		1.6	
25	9:00		1.6	
26	9:00		1.5	
27	9:00		1.5	
28	9:30		1.4	
29	9:00		1.5	
30	9:00		1.4	
31	9:00		1.4	

Was the chlorine residual ever less than the required minimum residual of mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

GWS Serving 3,300 or Fewer

If yes, did you monitor every four hours until the residual returned to _____ mg/L?
 Yes No

Attach those results and submit them with this form.

GWS Serving More Than 3,300

Did continuous monitoring equipment fail at any time this reporting month? Yes No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?
 Yes No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ //

Printed Name: Jeffrey Hintz

Title: owner

Operator Certification #: oesac #1820

Signature: _____

Phone #: (541) 592-2656

OR

Date: 02 / 03 / 2022

Small Groundwater System