

MAAR

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

Emile 6
4/1/21

System Name		Wayside Market	PWS ID#	41 94531
Month/Year		MAR 2021	Entry Point:	EP-A, Entry Point for Well
			Required Minimum Residual	0.2 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	12:30	KITCHEN	.3	
2	12:30	KITCHEN	.3	
3	1:05	KITCHEN	.3	
4	11:50	KITCHEN	.3	
5	11:30	KITCHEN	.3	
6	11:00	KITCHEN	.3	
7	12:50	KITCHEN	.3	
8	1:30	KITCHEN	.3	
9	11:30	KITCHEN	.3	
10	10:50	KITCHEN	.3	
11	10:45	KITCHEN	.25	ADDED BLEACH
12	11:50	KITCHEN	.3	
13	1:00	KITCHEN	.3	
14	11:50	KITCHEN	.3	
15	2:00	KITCHEN	.3	
16	1:00	KITCHEN	.3	
17	1:15	KITCHEN	.3	
18	11:45	KITCHEN	.3	
19	12:00	KITCHEN	.3	
20	2:00	KITCHEN	.3	
21	10:10	KITCHEN	.3	
22	12:00	KITCHEN	.3	
23	1:00	KITCHEN	.25	ADDED WATER & BLEACH
24	11:45	KITCHEN	.3	
25	2:30	KITCHEN	.3	
26	1:00	KITCHEN	.3	
27	12:25	KITCHEN	.25	ADDED MORE BLEACH
28	9:30	" "	.3	
29	8:17	" "	.2	
30	10:12	" "	.4	
31	5:00	" "	.3	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

<p>GWS Serving 3,300 or Fewer</p> <p>If yes, did you monitor every four hours until the residual returned to 0.2 mg/L? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300</p> <p>Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Attach grab sample results and submit them with this form.</p>
---	---

Printed Name: <u>Jeff Snoney</u> Signature: _____ Date: <u>4/1/21</u>	Title: <u>Manager</u> Phone #: <u>(511) 935-4665</u>	Operator Certification #: _____ OR _____ Small Groundwater System <input type="checkbox"/>
---	---	--