

**State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems**

MAY 23

System Name **Wayside Market**

PWS ID# **41 94531**

Month/Year **5 1 23** Entry Point: **EP-A, Entry Point for Well**

Required Minimum Residual **0.2 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	6:15	Filter	1.3	
2	7:00	" "	1.3	
3	8:15	" "	1.3	
4	9:00	" "	1.3	
5	6:20	" "	1.3	
6	8:00	" "	1.3	added bleach & water
7	8:00	" "	1.3	
8	2:15	" "	1.3	
9	5:15	" "	1.3	
10	6:00	" "	1.3	
11	7:00	" "	1.3	
12	7:15	" "	1.3	
13	8:00	" "	1.3	added Bleach & water
14	2:00	" "	1.3	
15	5:45	" "	1.3	
16	5:15	" "	1.3	
17	6:00	" "	1.3	
18	8:00	" "	1.3	
19	6:00	" "	1.3	
20	8:00	" "	1.3	added water & bleach
21	7:30	" "	1.3	
22	6:15	" "	1.3	
23	8:00	" "	1.3	
24	7:15	" "	1.3	
25	6:30	" "	1.3	
26	7:00	" "	1.3	
27	9:15	" "	1.3	added Bleach & water
28	8:30	" "	1.3	
29	6:15	" "	1.3	
30	7:00	" "	1.3	
31	6:00	" "	1.3	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? _____ hours

GWS Serving 3,300 or Fewer
 If yes, did you monitor every four hours until the residual returned to 0.2 mg/L?
 Yes No
 Attach these results and submit them with this form.

GWS Serving More Than 3,300
 Did continuous monitoring equipment fail at any time this reporting month? Yes No
 If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?
 Yes No
 Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /
 Date it was returned to service: / /

Printed Name: Chad Fisher
 Signature: Chad Fisher
 Date: 6/1/2023

Title: Asst Manager
 Phone #: (541) 938-4668

Operator Certification #: _____
 OR
 Small Groundwater System