

Nov '23

State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems

System Name **Wayside Market**

PWS ID# 41 94531

Month/Year **11 2023** Entry Point: **EP-A, Entry Point for Well**

Required Minimum Residual **0.2 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	6:56	Kitchen	.3	
2	6:58	" "	.3	
3	7:00	" "	.3	
4	7:15	" "	.3	added bleach & water
5	7:30	" "	.3	
6	7:30	" "	.3	
7	7:18	" "	.3	
8	6:11	" "	.3	
9	7:18	" "	.3	
10	7:20	" "	.3	
11	7:00	" "	.3	added water & Bleach
12	6:15	" "	.3	
13	7:30	" "	.3	
14	7:15	" "	.3	
15	6:15	" "	.3	
16	9:00	" "	.3	
17	6	" "	.3	
18	8:52	" "	.3	added water & Bleach
19	6:15	" "	.3	
20	5:20	" "	.3	
21	6:00	" "	.3	
22	5:48	" "	.3	
23	6:40	" "	.3	
24	7:00	" "	.3	
25	9:45	" "	.3	added water & Bleach
26	6:12	" "	.3	
27	7:12	" "	.3	
28	10:50	" "	.3	
29	7:52	" "	.3	
30	8:00	" "	.3	
31			.3	

Was the chlorine residual ever less than the required minimum residual of 0.2 mg/L?  Yes  No  
If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to 0.2 mg/L?  
 Yes  No

Attach these results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service?  
 Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed: / /

Date it was returned to service: / /

Printed Name: **Chad Fisher**

Title: **Asst Manager**

Operator Certification #:

Signature: **Chad Fisher**

Phone #: **541.938.4668**

OR

Date: **11-04-2023**

Small Groundwater System