

**State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems**

System Name Rodeway Inn Rice Hill

PWS ID# 41 94803

Month/Year 06/01/21

Entry Point: Hose at Pool House

Required Minimum Residual 1.0 mg/L

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1	11.40am	AA	1.2	
2	10.35am	AA	1.2	
3	1.25am	AA	1.2	
4	12.45am	AA	1.2	
5	12.20am	AA	1.2	
6	12am	AA	1.2	
7	1.10am	AA	1.2	
8	11.25am	AA	1.2	
9	12.35pm	AA	1.2	
10	10.20am	AA	1.2	
11	10.30am	AA	1.2	
12	10am	AA	1.2	
13	1pm	AA	1.2	
14	11.40am	AA	1.2	
15	12pm	AA	1.2	
16	11.25am	AA	1.2	
17	12pm	AA	1.2	
18	1.45pm	AA	1.2	
19	2pm	AA	1.2	
20	1.25pm	AA	1.2	
21	10.40am	AA	1.2	
22	11am	AA	1.2	
23	11.25am	AA	1.2	
24	12pm	AA	1.2	
25	12pm	AA	1.2	
26	1.20pm	AA	1.2	
27	2pm	AA	1.2	
28	12pm	AA	1.2	
29	1.45pm	AA	1.2	
30	10.25am	AA	1.2	
31		AA		

Was the chlorine residual ever less than the required minimum residual of \_\_\_\_\_ mg/L?  Yes  No  
 If yes, what was the longest time period until the required level was restored? \_\_\_\_\_ hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

**GWS Serving 3,300 or Fewer**

If yes, did you monitor every four hours until the residual returned to \_\_\_\_\_ mg/L as required?  Yes  No

Attach those results and submit them with this form.

**GWS Serving More Than 3,300**

Did continuous monitoring equipment fail at any time this reporting month?  Yes  No

If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required?  Yes  No

Attach grab sample results and submit them with this form.

Date continuous monitoring equipment failed:

/ /

Date it was returned to service:

/ /

Printed Name: TARLOCHAN SINGH

Title: GM

Signature: 

Phone #: (541)8493335

Operator Certification #:

OR

Small Groundwater System

Date: 06 / 30 / 21