## State of Oregon Drinking Water Program-Monthly Disinfection Report for Ground Water Systems

System Name Rodeway Inn Rice Hill P					WSID# 41 9	94803
Month/	Year 01/	01/22 Entry Po	int: Hose at F	Pool House Re	equired Minimum	Residual 1.0 mg/L
Date	Time	Source(s)	n use	Lowest free chlorine residual at entry point t distribution system (mg/		Notes
1	9.35am	AA		1.2		
2	9.45am	AA		1.2		
3	9.15am	AA		1.2		
4	9am	AA ·		1.2		
5	9.30am	AA		1.2		,
6	9.40am	AA		1.2	-	
7	10am	AA		1.2		
8	10.15am	AA	****	1.2		
9	10am	AA		1.2		•
10	10.10am	AA		1.2		<u>, , , , , , , , , , , , , , , , , , , </u>
11	9.30am	AA	4	1.2		
12	9.45am	AA		1.2		
13	1.15pm	AA	* -	1.2		
14	11.30am	AA		1.2		
15	10.40am	AA		1.2		
16	11.45am	AA .		1.2		
17	12pm	AA		1.2		
18	3pm	AA		1.2		
19	1.50pm	AA		1.2		
20	10.25am	AA		1.2		<u> </u>
21	11am	AA		1.2		6
22	1.pm	AA		1.2		
23	11.35am	AA		1.2		
24	9.35	AA	*	1.2		
25	10am	AA .		1.2		
26 27	10.40am	AA		1.2		
	11am	AA		1.2		
28 29	11am 9.45am	AA AA		1.2		
30	9.45am 9.15am	AA AA		1.2		
31	10am	AA		1.2		
Was the chlorine residual ever less than the required minimum residual of mg/L? ☐ Yes ☒ No						
If yes, what was the longest time period until the required level was restored? hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.						
GWS Serving 3,300 or Fewer				GWS Serving More Than 3,300		
until the residual returned to mg/L reporting mo						Date continuous monitoring equipment failed:
Attach those results and submit them with   co			continuous mo	If yes, were grab samples collected every four hours us continuous monitoring equipment was returned to serve required?  Yes No		Date it was returned to service:
			Attach grab sample results and submit them		with this form.	1 1
<i>3</i>				e: GM	Operator Certification #:	
Signature: full phone				ne #: (5418493335)	OR	
Date: 01	1/31 / 22 / '		Small Groundwater System 🗵			