State of Oregon Drinking Water Program Monthly Disinfection Report for Ground Water Systems

System Month/		Rodeway Inn Rice Hi /01/24 Entry Po			VS ID# 4.1 9 quired Minimum	94803 Residual 1.0 mg/L	
Date	Time	Source(s) i	n use	Lowest free chlorine residual at entry point to distribution system (mg/L		Notes	
1	11.25am	AA		1.2			
2	10.30am	AA		1.2			
3	9.50am	AA		1.2			
4	10.05am	AA		1.2			
5	11.30am	AA		1.2			
6	9.30am	AA		1.2			
7	10.10am	AA		1.2			
8	11.25am	AA		1.2			
9	9am	AA		1.2		The state of the s	
10	9.45am	AA		1.2			
11	10.10am	AA		1.2			
12	11.50am	AA		1.2			
13	9.45am	AA		1.2			
14	11am	AA		1.2			
15	11.25am	AA		1.2			
16	10am	AA		1.2			
17	9.25am	AA		1.2			
18	9.55am	AA		1.2			
19	11.40am	AA		1.2			
20	11.05am	AA		1.2			
21	9.15am	AA		1.2			
22	9am	AA		1.2			
23	9.10am	AA		1.2			
24	10am	AA		1.2			
25	9.45am	AA		1.2			
26	9am	AA ·	•	1.2			
27	11.45am	AA		1.2			
28	9.25am	AA		1.2			
29	9.15am	AA		1.2			
30	10.20am	AA		1.2			
31	10.204111	AA		1.2			
Was the	what was the	sidual ever less than the longest time period untiext business day.			☐ Yes ☒ No s – If > 4 hours, D	Prinking Water Program to be	
GWS Serving 3,300 or Fewer GWS Serving More Than 3,300						300	
until the	e residual ret		Did continuous monitoring equipment fail at any time this reporting month? ☐ Yes ☒ No		Date continuous monitoring equipment failed:		
as required? Yes No Attach those results and submit them with this form.			If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? Yes No Attach grab sample results and submit them with this form.		Date it was returned to service:		
Printed N	Name: TARL	OCHAN SINGH	Title: GM O		Operato	erator Certification #:	
Signatur	e:	m/	Phone #: (5418493335)		Small G	OR Small Groundwater System	