

State of Oregon Drinking Water Program  
Monthly Disinfection Report for Ground Water Systems

Sunny Wolf Charter Preschool			PWS ID# 41 95068	
System Name	Month/Year	Entry Point: Kitchen Sink	Required Minimum Residual	
November / 2025			1.03 mg/L	
Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1				
2				
3	7:00	Well	1.1	
4	7:00	Well	1.1	
5	6:30	Well	1.2	
6	6:40	Well	1.2	
7				
8				
9				
10	6:15	Well	1.2	
11	6:25	Well	1.2	
12	6:30	Well	1.2	
13	6:30	Well	1.2	
14				
15				
16				
17	6:35	Well	1.0	
18	6:40	Well	1.0	7:00 1.2 7:05 1.2
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29	7:20	Well	0.8	→ 7:25 0.4
30				
31				

Was the chlorine residual ever less than the required minimum residual of mg/L?  Yes  No

If yes, what was the longest time period until the required level was restored? :45 hours - If > 4 hours, Drinking Water Program to be notified by end of next business day.

<b>GWS Serving 3,300 or Fewer</b>		<b>GWS Serving More Than 3,300</b>
If yes, did you monitor every four hours until the residual returned to 1.2 mg/L as required? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No
Attach those results and submit them with this form.		If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No
		Attach grab sample results and submit them with this form.

Printed Name: Tiffany Gregory  
Signature: *Tiffany M Gregory*  
Date: 12/11/23

Title: Director/Teacher  
Phone #: (541) 761-8383

Operator Certification #: OR S-747398  
Small Groundwater System

Return by 10<sup>th</sup> of following month by either email [dwp.dmce@odhsosha.oregon.gov](mailto:dwp.dmce@odhsosha.oregon.gov); fax 971-673-0458;  
or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.

August 22, 2019