

State of Oregon Drinking Water Program
Monthly Disinfection Report for Ground Water Systems

System Name **Sunny Wolf Charter Preschool** PWS ID# **41 95068**
 Month/Year **Jan / 2020** Entry Point: **Kitchen Sink** Required Minimum Residual **1.03 mg/L**

Date	Time	Source(s) in use	Lowest free chlorine residual at entry point to distribution system (mg/L)	Notes
1				
2				
3				
4				
5				
6	6:37	well	1.0	→ retest 7:00 1.2
7	6:40	well	1.2	
8	6:40	well	1.2	
9				
10				
11				
12	6:45	well	1.0	→ 6:53 → 1.2
13	6:50	well	1.2	
14	6:40	well	1.2	
15	6:37	well	1.2	
16				
17				
18				
19				
20	6:40	well	1.2	
21	6:35	well	1.2	
22	6:40	well	1.2	
23				
24				
25				
26	6:40	well	1.2	
27	6:45	well	1.2	
28	6:35	well	1.2	
29	7:00	well	1.2	
30				
31				

Was the chlorine residual ever less than the required minimum residual of mg/L? Yes No
 If yes, what was the longest time period until the required level was restored? **5** hours – If > 4 hours, Drinking Water Program to be notified by end of next business day.

<p>GWS Serving 3,300 or Fewer If yes, did you monitor every four hours until the residual returned to 1.03 mg/L as required? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Attach those results and submit them with this form.</p>	<p>GWS Serving More Than 3,300 Did continuous monitoring equipment fail at any time this reporting month? <input type="checkbox"/> Yes <input type="checkbox"/> No If yes, were grab samples collected every four hours until the continuous monitoring equipment was returned to service as required? <input type="checkbox"/> Yes <input type="checkbox"/> No Attach grab sample results and submit them with this form.</p>	<p>Date continuous monitoring equipment failed: / / Date it was returned to service: / /</p>
---	--	---

Printed Name: **Tiffany Gregory** Title: **Director/Teacher** Operator Certification #: **S-747398**
 Signature: *Tiffany Gregory* Phone #: **(541) 761-8383** OR
 Date: **2/9/20** Small Groundwater System

Return by 10th of following month by either email dwp.dmce@odhsoha.oregon.gov; fax 971-673-0458; or mail to Drinking Water Services, PO Box 14350, Portland, OR 97293-0350.