

**State of Oregon Drinking Water Section
Monthly UV Disinfection Report for Ground Water Systems Requiring 4-log Viral Inactivation**

System Name Salmon Run Golf Course

PWS ID# 41 95127

Month/Year 09/2021 Entry Point: A

Required Minimum Dose 186 mJ/cm²

Date	Time	Source(s) in use	Any UV Alarms? (Y/N)	Notes
1		Well, SRC-AA	Y	Boil water notice in-place
2		Well, SRC-AA	Y	Boil water notice in-place
3		Well, SRC-AA	Y	Boil water notice in-place
4		Well, SRC-AA	Y	Boil water notice in-place
5		Well, SRC-AA	Y	Boil water notice in-place
6		Well, SRC-AA	Y	Boil water notice in-place
7		Well, SRC-AA	Y	Boil water notice in-place
8	15:34	Well, SRC-AA	N	Boil water notice in-place
9	10:27	Well, SRC-AA	N	Boil water notice in-place. Special Distribution BacT sample taken.
10		Well, SRC-AA		Boil water notice in-place
11		Well, SRC-AA		Boil water notice lifted.
12		Well, SRC-AA		
13		Well, SRC-AA		
14		Well, SRC-AA		
15	09:56	Well, SRC-AA	N	
16		Well, SRC-AA		
17		Well, SRC-AA		
18		Well, SRC-AA		
19		Well, SRC-AA		
20		Well, SRC-AA		
21		Well, SRC-AA		
22	13:10	Well, SRC-AA	N	
23		Well, SRC-AA		
24		Well, SRC-AA		
25		Well, SRC-AA		
26		Well, SRC-AA		
27		Well, SRC-AA		
28		Well, SRC-AA		
29		Well, SRC-AA		
30	13:16	Well, SRC-AA	N	
31		Well, SRC-AA		

Was the minimum UV dose ever less than the required dose of 186 mJ/cm²? Or was the alarm ever triggered? Yes No
 If yes, was a boil notice issued, and DWS contacted? If not, please explain: 8/20 system went into alarm. DWS notified. 9/8 new UV comp board installed. BacT samples taken 9/9. Results were negative on 9/11. DWS notified and approved lifting boil notice.

This form is for groundwater systems where no residual disinfection has been required to prevent regrowth of pathogens in the pipes.

Date & time UV reactor failed:
08 / 20 / 2021 12:01 am/pm
 Date & time it was returned to service:
09/08/2021 15:30 am/pm

Printed Name: Mark Haglund

Title: Operations Supervisor

Operator Certification #: T-6161 FE

Signature: 

Phone #: (541) 412-0424

OR

Date: 10 / 01 / 2021

Small Groundwater System