

State of Oregon Drinking Water Section
Monthly UV Disinfection Report for Ground Water Systems Requiring 4-log Viral Inactivation

System Name Salmon Run Golf Course

PWS ID# 4 1 95127

Month/Year March 2026 Entry Point: A

Required Minimum Dose  186 mJ/cm²

Date	Time	Source(s) in use	Any UV Alarms? (Y/N)	Notes
1		Well, SRC-AA		
2	0806	Well, SRC-AA	N	
3		Well, SRC-AA		
4		Well, SRC-AA		
5		Well, SRC-AA		
6		Well, SRC-AA		
7		Well, SRC-AA		
8		Well, SRC-AA		
9	0841	Well, SRC-AA	N	
10		Well, SRC-AA		
11		Well, SRC-AA		
12		Well, SRC-AA		
13		Well, SRC-AA		
14		Well, SRC-AA		
15		Well, SRC-AA		
16		Well, SRC-AA		
17	0814	Well, SRC-AA	N	
18		Well, SRC-AA		
19		Well, SRC-AA		
20		Well, SRC-AA		
21		Well, SRC-AA		
22		Well, SRC-AA		
23	1319	Well, SRC-AA	N	
24		Well, SRC-AA		
25		Well, SRC-AA		
26		Well, SRC-AA		
27		Well, SRC-AA		
28		Well, SRC-AA		
29		Well, SRC-AA		
30	0913	Well, SRC-AA	N	
31		Well, SRC-AA		

Was the minimum UV dose ever less than the required dose of 186 mJ/cm²? Or was the alarm ever triggered? Yes No
 If yes, was a boil notice issued, and DWS contacted? If not, please explain:

This form is for groundwater systems where no residual disinfection has been required to prevent regrowth of pathogens in the pipes.

Date & time UV reactor failed: am pm
 Date & time it was returned to service: am pm

Printed Name: Brenda L Vasquez Title: DRC
 Signature: Brenda L Vasquez Phone #: (541) 254-1909
 Date: 03/08/2026

Operator Cert #: T2-D1 070226
 OR
 Small Groundwater System